## Pool Safety and Maintenance Checklist

This checklist can be used to document your seasonal, monthly, and daily safety and maintenance inspection.

General Off-Season Checklist	Pass	Fail	Problem / Solution
Fence is 48" to 54" in height.			
Bottom of fence is no higher than 4" from the ground.			
Fence balusters are no wider than 4" apart.			
Overhead exterior lighting is installed and operational.			
Restroom facilities have been winterized.			
Pool circulation equipment has been winterized.			
Pool furniture has been properly stored.			
Pool safety cover has been installed.			
If spa is present, winterize spa pumping equipment.			
If spa is present, install safety cover.			
Off-Season Checklist (Monthly)	Pass	Fail	Problem / Solution
Pool fence gate is locked and secured.			
Building is locked and secured.			
Pool safety cover is installed and in good condition.			
In-Season Start-Up Checklist	Pass	Fail	Problem / Solution
Gate is self-closing and is operating properly.			
Safety lock is properly installed and operational.			
Pool furniture is safely arranged and unobstructed.			
No pool furniture is closer than 4' to entrance gate.			
Safety signage is installed in location, and clearly visible in the pool area.			
Pool deck is smooth and level with no trip or fall hazards.			
No Lifeguard on Duty signage is posted if applicable.			
Pool hours of operation are clearly posted.			
Emergency phone number signage is posted.			
Emergency phone is installed.			
Emergency safety equipment is present (deep depth floating rope, floating ring with rope attached, throw floating buoy, and emergency back board).			
Depth indicators are clearly visible from in the pool and from pool deck.			
Pool circulation equipment is inspected and associated gauges are working properly.			
If present, open restroom for the season.			
Make sure bathroom floor is a nonslip surface and is free of any trip and fall hazards.			

## Pool Safety and Maintenance Checklist

Test water temperature in bathroom to make sure it does not exceed 120 degrees in temperature.								
If spa is present, ensure spa safety signage is present.								
If spa/hot tub is present, ensure the water temperature does not exceed 104 degrees.								
If spa is present, ensure emergency shut off is present and easily accessible.								
Inspect drain covers and pool skimmer covers to makes sure they are VGB (Virginia Graeme Baker Pool and Spa Safety Act) compliant. This applies for both pools and spas.								
In-Season Monthly Inspections	Pass	Fail			Problem	/ Solution	1	
Inspect and test gate lock to ensure it's operating properly.								
Inspect the condition of the fence to make sure it's in sound condition.								
Inspect pool deck to make sure it's smooth and level with no slip, trip, or fall hazards.								
Inspect condition and placement of the pool furniture.								
Inspect pump pool.								
In-season documentation for w	ater t	esting	frequen	y may v	ary for ea	ch test.		
In-season documentation for w	ater to	esting M	frequenc T	y may v	ary for ea	ch test. F	S	S
In-season documentation for was alt if used (2700 to 3400 ppm)	ater to						S	S
	rater to						S	S
Salt if used (2700 to 3400 ppm)	rater to						S	S
Salt if used (2700 to 3400 ppm)  Free chlorine (1.0 to 3.0 ppm)	rater to						S	S
Salt if used (2700 to 3400 ppm)  Free chlorine (1.0 to 3.0 ppm)  PH (7.2 to 7.8)	rater to						S	S
Salt if used (2700 to 3400 ppm)  Free chlorine (1.0 to 3.0 ppm)  PH (7.2 to 7.8)  Cyanuric acid stabilizer	rater to						S	S
Salt if used (2700 to 3400 ppm)  Free chlorine (1.0 to 3.0 ppm)  PH (7.2 to 7.8)  Cyanuric acid stabilizer  Outdoor pools (30 to 50 ppm)	rater to						S	S
Salt if used (2700 to 3400 ppm)  Free chlorine (1.0 to 3.0 ppm)  PH (7.2 to 7.8)  Cyanuric acid stabilizer  Outdoor pools (30 to 50 ppm)  Indoor pools (0ppm)	ater to						S	S
Salt if used (2700 to 3400 ppm)  Free chlorine (1.0 to 3.0 ppm)  PH (7.2 to 7.8)  Cyanuric acid stabilizer  Outdoor pools (30 to 50 ppm)  Indoor pools (0ppm)  Total alkalinity (80 to 120 ppm)	rater to						S	S
Salt if used (2700 to 3400 ppm)  Free chlorine (1.0 to 3.0 ppm)  PH (7.2 to 7.8)  Cyanuric acid stabilizer  Outdoor pools (30 to 50 ppm)  Indoor pools (0ppm)  Total alkalinity (80 to 120 ppm)  Calcium hardness (200 to 400 ppm)	rater to						S	S
Salt if used (2700 to 3400 ppm)  Free chlorine (1.0 to 3.0 ppm)  PH (7.2 to 7.8)  Cyanuric acid stabilizer  Outdoor pools (30 to 50 ppm)  Indoor pools (0ppm)  Total alkalinity (80 to 120 ppm)  Calcium hardness (200 to 400 ppm)  Metals (0 ppm)	rater to						S	S
Salt if used (2700 to 3400 ppm)  Free chlorine (1.0 to 3.0 ppm)  PH (7.2 to 7.8)  Cyanuric acid stabilizer  Outdoor pools (30 to 50 ppm)  Indoor pools (0ppm)  Total alkalinity (80 to 120 ppm)  Calcium hardness (200 to 400 ppm)  Metals (0 ppm)  Saturation index (2 to .2 (0 best))	rater to						S	S
Salt if used (2700 to 3400 ppm)  Free chlorine (1.0 to 3.0 ppm)  PH (7.2 to 7.8)  Cyanuric acid stabilizer  Outdoor pools (30 to 50 ppm)  Indoor pools (0ppm)  Total alkalinity (80 to 120 ppm)  Calcium hardness (200 to 400 ppm)  Metals (0 ppm)  Saturation index (2 to .2 (0 best))							S	S
Salt if used (2700 to 3400 ppm)  Free chlorine (1.0 to 3.0 ppm)  PH (7.2 to 7.8)  Cyanuric acid stabilizer  Outdoor pools (30 to 50 ppm)  Indoor pools (0ppm)  Total alkalinity (80 to 120 ppm)  Calcium hardness (200 to 400 ppm)  Metals (0 ppm)  Saturation index (2 to .2 (0 best))  Inspector name, signature, and completion date				w		F		S

