

Earth Science Laboratories, Inc.
113 S.E. 22nd St., Suite 1
Bentonville, Arkansas 72712Phone 800.257.9283
Fax 479.271.7693
www.earthsciencelabs.com**FIFRA Section 2(ee)
Recommendation****Product Bulletin
Technical Information****EarthTec – Use of Reduced Rates for Control
of Algae, Nonpublic Health Bacteria, and
Bacteria That Cause Odor Problems in the
State of New York****EPA Reg. Number: 64962-1**

This recommendation is made as permitted under FIFRA section 2(ee) and has not been submitted to or approved by the federal EPA.

Pesticide applicator certification and a permit from the New York State Department of Environmental Conservation may be required for sale, possession, or use. Contact the Pesticide Control Specialist at your NYSDEC regional office prior to the proposed application for specific conditions or exemptions.

All applicable directions, restrictions, precautions and Conditions of Sale and Warranty on the EPA registered label are to be followed. Refer to the container label for additional instructions. Always read and follow label directions. Information contained in this Technical Information Bulletin is not intended to replace or amend any product labeling. Always read and follow all label directions when using any pesticide alone or in tank mix combinations. For use in controlling algae and cyanobacteria at all aquatic application sites do not exceed a copper concentration in water of 1.0 ppm of metallic copper concentration (background + applied).

The user must have this recommendation in their possession at the time of use.

Directions for Use – Open Waters

Apply a dose no more than 3 parts per million EarthTec (i.e., 3 gallons of EarthTec per million gallons of water treated, equivalent to 1 gallon of EarthTec per acre-foot), yielding a concentration of 0.18 mg/L (ppm) as metallic copper. Supplemental applications are permissible as long as no more than a cumulative total of 0.18 mg/L as copper is applied in any given 14-day period.

Dose (ppm by volume)	gals/MG*	gals/ac-ft	Cu²⁺ (mg/L)
0.5	0.5	0.15	0.030
1	1	0.3	0.060
2	2	0.7	0.120
3	3	1.0	0.180

*MG = million gallons

Directions for Use – Infrastructure and Flowing Waters

For protection of pipelines and other infrastructure by addition to flowing waters, use a metering pump to deliver a dose equivalent to 0.5 to 3.0 uL/L of product, equivalent to 0.03 to 0.18 mg/L as copper.