



Factory Authorized Pre-Startup Checklist

Company Name: _____ Contact: _____

Site Address: _____ City: _____ State: _____ Zip: _____

Machine Model: _____ S/N: _____

The following checklist is to ensure your equipment is ready for factory authorized startup. This will ensure proper startup and eliminate delays and/or additional costs. Please call with any questions.

- Yes No – Have you reviewed the instruction manual?
- Yes No – Is the equipment installed in accordance to the instruction manual?
- Yes No – Is electrical complete, grounded, protected against short circuit as per local/state code?
- Yes No – Check and record incoming voltage each leg to ground: L1____ L2____ L3____
- Yes No – Check and record incoming voltage leg to leg: L1/L2:____ L1/L3:____ L2/L3:____
- Yes No – Starter to control panel interconnect complete? (external starters only)
- Yes No – Air connection complete to air system with properly sized shut-off valve?
- Yes No – Cooling water connections completed with shut-off valves, solenoid valve and strainer, where applicable?
- Yes No – Equipment and equipment room properly vented and filtered?
- Yes No – Condensate drain valves piped according to instruction manual?
(manual and automatic)
- Yes No – Equipment is available for Lockout/Tag Out to be removed for startup?
- Yes No – Is safety or site training required for the Atlas Copco technician prior to start up?
If Yes, how many hours required? _____
- Yes No – Any site or union restrictions that may affect the Atlas Copco technician’s startup?

Additional Comments:

Customer Signature: _____ Date: _____