

**PUBLIC REGISTER OF INFORMATION**
**Water Quality Summary Date Range:** 01 January 2021 to 31 December 2021

**Treatment Works:** Oldford Treated

**Prescribed Concentration Values**

<b>Test Description</b>	<b>No. of Samples</b>	<b>No. of Failures</b>	<b>Min</b>	<b>Mean</b>	<b>Max</b>	<b>PCV</b>	<b>Units</b>
Coliforms Confirmed	365		0.00	0.00	0.00	0	cfu/100mL
E.Coli Confirmed	365		0.00	0.00	0.00	0	cfu/100mL
Total Coliforms (Confirmed)	365		0.00	0.00	0.00	0	cfu/100mL
Clostridia Perfringens Confirmed	54		0.00	0.00	0.00	0	cfu/100mL
Colony Count after 3 days @22C	365		0.00	0.10	7.00		cfu/mL
Field Free Chlorine	365		0.33	0.53	0.72		mg/L
Field Total Chlorine	365		0.35	0.58	0.74		mg/L
Conductivity	53		570.00	596.83	620.00	2500	uS/cm
Turbidity - Indicator	365		0.13	0.15	0.48	1	ntu
Benzene	8	<	0.06	0.06	0.06	1	µg/l
Boron Total	8		41.70	45.25	51.10		µg/l
Chloride as Cl	8		19.50	19.76	20.20	250	mgCl/l
Cyanide Total as CN	8	<	1.20	4.96	5.50	50	µgCN/l
Fluoride	8		330.00	356.25	390.00	1500	µg/l
Gross Alpha	8		0.04	0.05	0.07		Bq/L
Gross Beta	8		0.08	0.10	0.11		Bq/L
Mercury Total	8	<	0.06	0.06	0.06		µgHg/l
Nitrate as NO3	8		26.00	27.11	27.85		mgNO3/l
Nitrite as NO2	8	<	0.00	0.00	0.00	0.1	mgNO2/l
Total Oxidised Nitrogen	8		26.00	27.11	27.85		mg/L
Nitrogen Formula	8		0.52	0.54	0.56		mg/L
Sulphate	8		37.50	38.09	39.50	250	mgSO4/l
Total organic Carbon	8		0.60	0.69	0.71	0.0	mg/L
1,2 Dichloroethane	8	<	0.16	0.16	0.16	3	µg/l
Tetrachloroethene	8	<	0.45	0.45	0.45		µg/l
Trichloroethene	8	<	0.40	0.40	0.40		µg/l

**Prescribed Concentration Values**

---

<b>Test Description</b>	<b>No. of Samples</b>	<b>No. of Failures</b>	<b>Min</b>	<b>Mean</b>	<b>Max</b>	<b>PCV</b>	<b>Units</b>
Total Chlorethenes	8		0.85	0.85	0.85	10	µg/l
Tetrachloromethane	8		< 0.16	0.16	0.16	3	µg/l